

Treidchim West Ltd
 Kryvonosa Str. 12B/5
 Lviv, 79000
 Ukraine

 T + 32 3 205 16 66
 F + 32 3 233 93 83
 E sales@solventis.net

www.solventis.net

 Date: 19/09/2023
 Our ref.: SN129493
 Your ref.: Contract N° DA-TRW 001/2022 dd 04/04/2022

CERTIFICATE OF ANALYSIS

Coolant C2053E

Premium MEG Based OAT Coolant Concentrate

Parameter	Unit	Method	Specification		Result
			min	max	
Appearance	-	Visual	Bright and Clear		Bright and Clear
Water Content	% (m)	ASTM D1123		3	3
Density @ 20°C	g/cm ³	ASTM D4052	1.105	1.125	1.1189
pH (50% vol)	-	ASTM D1287	7.5	9.0	8.07
Reserve Alkalinity	ml 0.1N HCl	ASTM D1121	5		6.23

Typical Values:

Parameter	Unit	Method	Specification		Typical Data
			min	max	
Freezing Point (50% vol)	°C	ASTM D1177	-	-36.4	-38
Ash Content	% (m)	ASTM D1119	-	5	2
Foaming Volume	ml	ASTM D1881	-	150	40
Foam Break Time	s	ASTM D1881	-	5	2

PRODUCTION AUG 2023 - EXPIRY AUG 2025

